

### COOLEDGE LIGHT QUALITY METRICS: FABRILUM TUNABLE WHITE 2700K-5700K (BOTH CHANNELS @50%)

#### NOTES ABOUT LIGHT QUALITY METRICS DATA:

- Values shown are TYPICAL actual performance of individual units may vary
- The data presented has been generated in accordance with LM-79-08
- Spectral and color rendering data is applicable to all luminaire sizes, models, and flux levels of FABRILum including:
  - Spectral Power Distribution (SPD)
  - Nominal CCT
  - Chromaticity
  - $-R_f$  and  $R_g$  (TM-30-15)
  - CRI (R<sub>a</sub>) and R-values
  - D<sub>uv</sub>

#### **SELECTED DEFINITIONS**

- Candlepower: As presented in this document it is the same as "candela" the SI unit of measurement for light intensity.
- CRI (R<sub>a</sub>): The general Color Rendering Index based on 8 CIE reference pastel color samples.
- D<sub>uv</sub>: The American National Standards Institute (ANSI) references D<sub>uv</sub>, a metric based on the CIE 1976 color space that quantifies the distance between the chromaticity of a given light source and a blackbody radiator of equal CCT. A negative D<sub>uv</sub> indicates that the source is "below" the Planckian locus (blackbody curve), potentially having a red/blue tint, whereas a positive D<sub>uv</sub> indicates that the source is "above" the curve, potentially exhibiting a green tint.
- Nominal CCT Quadrangles: ANSI has defined acceptable chromaticity quadrangles for LED binning in relation to
  the blackbody curve within CIE color space. The data presented shows the typical chromaticity coordinate within the
  relevant quadrangle.
- R-value (R<sub>i</sub>): The R-value is a mathematical calculation measuring how similar a light source renders a particular color compared to a reference blackbody source of the same CCT. R-values are not absolute and therefore cannot be used as a specific measurement of color rendering. For example, a 2700K source may have a lower R9 value than a 5700K source, however, in absolute terms the 2700K source will render saturated red much better than the 5700K source because of the relative abundance of red in the spectral power distribution (SPD) for the 2700K source in comparison.
- R1-R15: The data presented include the special CRI set of CIE 14 samples and the Japanese Industrial Standard (JIS) for R15.
- R; The IESNA TM-30-15 technical memorandum for measuring color rendering defines a "fidelity" index, R, that is similar to CRI and quantifies the average difference in appearance between the test source and a reference source based on 99 reference colors.
- R<sub>g</sub>: The IESNA TM-30-15 technical memorandum for measuring color rendering defines a "gamut" index, R<sub>g</sub>, that
  quantifies the average difference in color saturation between the test source and a reference source based on 99
  reference colors.



# COOLEDGE LIGHT QUALITY METRICS: FABRILUM TUNABLE WHITE 2700K-5700K (BOTH CHANNELS @50%)

DATA SHOWN IS BASED ON A 4' X 6' (1200MM X 1800MM) TEST LUMINAIRE

#### LIGHTING PROPERTIES: TYPICAL PERFORMANCE


#### **TEST CONDITIONS**

Temp (°C)	DC Voltage (V)	Current (A)	Power (W)
23.0	120	1.64	197

## COLOR RENDERING INDEX DETAILS

INDEX DETAILS				
Refernce	Value			
R1	98			
R2	99			
R3	98			
R4	95			
R5	96			
R6	95			
R7	94			
R8	91			
R9	84			
R10	99			
R11	96			
R12	76			
R13	99			
R14	99			
R15	97			

#### NOMINAL CCT QUADRANGLES



#### **CHROMATICITY COORDINATES**

Chromaticity (x)	0.4011	
Chromaticity (y)	0.3808	
Chromaticity (u)	0.2371	
Chromaticity (v)	0.3376	
Chromaticity (u')	0.2371	
Chromaticity (v')	0.5064	
Duv	-0.0035	


#### SUMMARY OF RESULTS

Total Lumen Output	13450 Lumens	
Luminaire Efficacy	68.3 lm/W	
Maximum Candela	5010 Candela	
CCT	3511 K	
CRI	96	
R9	84	
TM-30 R <sub>f</sub>	90	
TM-30 R <sub>g</sub>	99	

## INTENSITY (CANDLEPOWER) SUMMARY


Angle	Mean CP	Lumens	
0	100%	100%	
5	99%		
10	98%	98%	
15	95%		
20	91%	92%	
25	88%		
30	30%	81%	
35	78%		
40	71%	65%	
45	63%		
50	55%	47%	
55	47%		
60	39%	29%	
65	31%		
70	23%	13%	
75	16%		
80	9%	4%	
85	3%		
90	0%		

#### SPECTRAL POWER DISTRIBUTION (SPD)



Testing was performed in accordance with LM-79-08.

#### **POLAR GRAPH**



W cooledgelighting.com