### **FABRICore**

### LIGHT QUALITY METRICS - 3000K



### NOTES ABOUT LIGHT QUALITY METRICS DATA:

- · Values shown are TYPICAL actual performance of individual units may vary
- The data presented has been generated in accordance with LM-79-08
- A complete summary of LM-79-08 data is provided for nominal 4' x 4' (1200mm x 1200mm) FABRICore models only; however, spectral and color rendering data is applicable to all luminaire sizes, models, and flux levels including:
  - Spectral Power Distribution (SPD)
  - Nominal CCT
  - Chromaticity
  - $-R_f$  and  $R_g$  (TM-30-15)
  - CRI (R<sub>a</sub>) and R-values
  - D<sub>...</sub>

### SELECTED DEFINITIONS

- · Candlepower: As presented in this document it is the same as "candela" the SI unit of measurement for light intensity.
- CRI (R<sub>2</sub>): The general Color Rendering Index based on 8 CIE reference pastel color samples.
- $D_{uv}$ : The American National Standards Institute (ANSI) references  $D_{uv}$ , a metric based on the CIE 1976 color space that quantifies the distance between the chromaticity of a given light source and a blackbody radiator of equal CCT. A negative  $D_{uv}$  indicates that the source is "below" the Planckian locus (blackbody curve), potentially having a red/blue tint, whereas a positive  $D_{uv}$  indicates that the source is "above" the curve, potentially exhibiting a green tint.
- Nominal CCT Quadrangles: ANSI has defined acceptable chromaticity quadrangles for LED binning in relation to the blackbody curve within CIE color space. The data presented shows the typical chromaticity coordinate within the relevant quadrangle.
- R-value (R<sub>i</sub>): The R-value is a mathematical calculation measuring how similar a light source renders a particular color compared to a reference blackbody source of the same CCT. R-values are not absolute and therefore cannot be used as a specific measurement of color rendering. For example, a 2700K source may have a lower R9 value than a 5700K source, however, in absolute terms the 2700K source will render saturated red much better than the 5700K source because of the relative abundance of red in the spectral power distribution (SPD) for the 2700K source in comparison.
- R1-R15: The data presented include the special CRI set of CIE 14 samples and the Japanese Industrial Standard (JIS) for R15
- R<sub>r</sub>: The IESNA TM-30-15 technical memorandum for measuring color rendering defines a "fidelity" index, R<sub>r</sub>, that is similar to CRI and quantifies the average difference in appearance between the test source and a reference source based on 99 reference colors.
- $R_g$ : The IESNA TM-30-15 technical memorandum for measuring color rendering defines a "gamut" index,  $R_g$ , that quantifies the average difference in color saturation between the test source and a reference source based on 99 reference colors.

www.cooledgelighting.com R00 04142021 (A4) 1/2

# FABRICore | LIGHT QUALITY METRICS - 3000K LUMINAIRE 4' X 4' (1200MM X 1200MM)



### LIGHTING PROPERTIES: TYPICAL PERFORMANCE


#### **TEST CONDITIONS**

Temp (°C)	DC Voltage (V)	AC Current (A)	Input Power (W)
23.0	120	1.08	130

## COLOR RENDERING INDEX DETAILS

Reference	Value	
R1	95	
R2	99	
R3	98	
R4	93	
R5	94	
R6	96	
R7	91	
R8	83	
R9	64	
R10	95	
R11	94	
R12	81	
R13	96	
R14	100	
R15	91	

### NOMINAL CCT QUADRANGLES



#### CHROMATICITY COORDINATES

Chromaticity (x)	0.4387	
Chromaticity (y)	0.3991	
Chromaticity (u)	0.2539	
Chromaticity (v)	0.3465	
Chromaticity (u')	0.2539	
Chromaticity (v')	0.5197	
Duv	-0.0022	


#### SUMMARY OF RESULTS

Total Lumen Output	9700 Lumens	
Luminaire Efficacy	74.6 lm/W	
Maximum Candela	3549 Candela	
CCT	2929 K	
CRI (Ra)	94	
Duv	-0.0022	
TM-30 R <sub>f</sub>	90	
$TM-30 R_g$	98	

## INTENSITY (CANDLEPOWER) SUMMARY

Mean CP	Lumens	
100%	100%	
99%		
98%	000/	
95%	98%	
91%	010/	
87%	91%	
82%	79%	
76%	19%	
69%	63%	
62%	03/0	
55%	45%	
48%	45%	
41%	28%	
33%		
26%	13%	
18%		
11%	3%	
5%		
0%		
	100% 99% 98% 95% 91% 87% 82% 76% 69% 62% 55% 48% 41% 33% 26% 18% 11% 5%	

### SPECTRAL POWER DISTRIBUTION (SPD)



Testing was performed in accordance with LM-79-08.

### POLAR GRAPH

